



Certificate of Compliance

Certificate: 2341214

Master Contract: 202993

Project: 2413772

Date Issued: April 27, 2011

Issued to: International Metal Engineering

Blk 13 Toa Payoh Lorong 8 06-05

Braddell Tech Park

Singapore, 319261

Singapore

Attention: Max Angelo Vijaya

The products listed below are eligible to bear the CSA Mark shown



Ron Wildish

Issued by: Ron Wildish

PRODUCTS

CLASS 4418 02 - OUTLET BOXES AND FITTINGS - Boxes - For Hazardous Locations

Class I, Div. 1, Groups B, C and D; Class II, Div. 1, Groups E, F and G, Class III, Div. 1; Type 4X:

8117Pa-b – Instrument Enclosure – Epoxy coated cast aluminum, with window or blind cover; Ambient: -40 Deg. C to + 85 Deg. C.

a = Model B or D.

b = Entry Type: 05, 07 or 18

Note: The above housings are Certified for use only with other equipment where the suitability of the combination is to be determined by the CSA International.

APPLICABLE REQUIREMENTS

C22.2 No. 0-10 - General Requirements – Canadian Electrical Code, Part II

C22.2 No. 25-1966 - Enclosures for Use in Class II, Groups E, F and G Hazardous Locations



Certificate: 2341214

Master Contract: 202993

Project: 2413772

Date Issued: April 27, 2011

C22.2 No. 30-M1986 - Explosion-Proof Enclosures for Use in Class I Hazardous Locations

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures



Supplement to Certificate of Compliance

Certificate: 2341214

Master Contract: 202993

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2413772	April 27, 2011	Update of report 2341214 to cover addition of alternative CSA-accepted adhesive labels.
2341214	October 12, 2010	Model 8117PB and 8117PD Instrument Enclosures for Class I, Class II and Class III, Div. 1 Hazardous locations (Type 4X).